


THE KLAMATH TRIBES



INVITATION

FOR

BID

ADDENDUM #1

ADMINISTRATION BUILDING ROOF REPLACEMENT

IFB 04-26


SCOPE OF WORK/QUESTIONS/DESIGNS

CLOSES: 3:00 PM MARCH 23, 2026

The Klamath Tribes is issuing Addendum #1 to address questions regarding the scope of work listed for IFB 04-26, extend time for questions, and issue designs from original roof installation.

- 1. Adding Task to Scope of Work:** Remove old gutters and install new gutters. The color should be the same or close to original color.
- 2. Task Clarification:** No less than a 4" insulation on overlaid roof. Need the insulation value of R-49. If the existing roof is replaced install same amount of insulation that's been previously installed.
- 3. Task Clarification:** Damaged Vinyl Back Insulation to be removed and replaced.
- 4. Task Clarification:** The gauge of the overlay/new roof is to be 24 gauge.
- 5. Task Clarification:** Manufacturer's warranty is required.
- 6. Receipt of Questions of Inquiry:** Extended from 4:00 pm, Friday 3/16/2026 to 4:00 pm Thursday, 3/19/2026.
- 7. Attachments:** One (1) available drawing by Robert J Bogatay Construction and James D. Matteson Architect is attached for reference. The original design plans are unable to be found.
- 8. Clarification:** Administration Building was constructed in 2001. Original roof is no longer under warranty with the building manufacturer.

THESE DRAWINGS IDEAS AND DETAILS ARE PROPERTY OF AND NOT TO BE REPRODUCED WITHOUT PERMISSION OF
 ARCHITECTURAL DESIGN GROUP
 1111 N. KENT ST. #1000
 CHICAGO, ILL. 60610
 TEL: (312) 467-1000
 FAX: (312) 467-1001
 WWW: WWW.ADG.COM



REVISIONS
 NO. DATE BY
 1 0000 0000 0000